

EVS25

Shenzhen, China, Nov 5-9, 2010

Considering Hydrogen Fuel Cells Powertrain as Power Generation Plant

Mario Valentino Romeri

Independent Consultant, 60027 Osimo, ITALY, Valentino.Romeri@Alice.it

Abstract

Every day more than 90% of vehicles are parked, even during peak traffic hours. In this situation, the vehicle power generation system hydrogen fuel cell based (H2FC Powertrain), if properly equipped, could become a new power generation source, supplying electricity to homes and to the grid like a new type of distributed generation: Vehicle-to-Grid (V2G). The V2G concept is well known but, in the paper, the H2FC Powertrain is considered as power generation plant and, based only on public data, it is compared with the traditional power generation technologies. The results are surprising. Using only tested H2FC Powertrain data (DOE 2009, referred to projected high volume production) we found that the cost generating baseload electricity would be in a range of USD 179,2 - 196,7 for MWh. Comparing this cost range with the levelised costs of electricity (LCOE) published in the most recent studies, H2FC Powertrain generation would be at lower cost than wind offshore, solar thermal and solar photovoltaic. However, using the 2015 DOE data target the of H2FC Powertrain, electricity production cost range moves to USD 106,6 - 156,6 for MWh, and, in most of the context, it appears competitive with all the power generation technologies.

Keywords: Fuel Cell Vehicle, Hydrogen, Vehicle-to-Grid, Power Generation Plant, LCOE.

1. The Vehicle-to-Grid Concept

Currently more than 90% of vehicles are parked, even during peak traffic hours. In this situation the vehicle power generation system fuel cell based (H2FC powertrain), if properly equipped, could become a new power generation source, supplying electricity to homes and to the grid like a new type of distributed generation: Vehicle-to-Grid (V2G).

Academics, public and private operators well know the V2G concept [1, 2, and 3]. V2G could be realized indifferently with Electric Vehicles (EV) and Fuel Cell Vehicles (FCV), but only in the case of FCV, we are in presence of a real new power generation capacity GHG emission free: the H2FC powertrains.

FCV in a V2G mode may profitably provide power to the grid when they are parked and connected to an electrical outlet. In this perspective, literature analyzed also the economic aspects [4, 5]. FCV have significant potential revenue streams from V2G, on peak power production, but it is possible to obtain higher return offering a series of high-value ancillary services to the grid. If well implemented, the FCV potential revenue streams from V2G could help to reduce the initial high FCV costs, reducing in this way also the amount of public subsidy and incentives that all the current introduction scenarios needed in order to support the introduction of this low-carbon transport technology by 2020.

If FCV, properly equipped and parked in V2G mode, become a new power generation source supplying

electricity to homes and to the grid, it could be useful to begin to analyze the H2FC powertrain relevance in the power generation sector.

In this perspective, in the paper the H2FC powertrain is considered as power generation plant and, based only on public data, the cost of electricity production is compared with the generation costs of the traditional power generation technologies in a simple and preliminary analysis.

2. Levelized Cost of Electricity (LCOE) Generation

2.1 Definition

According to OECD/IEA-NEA (IEA) [6] the levelized costs of generating electricity (LCOE) approach is a financial model used for the analysis of generation costs.

Focus of the estimated average LCOE is the entire operating life of the power plants for a given technology. In this model, different cost components are taken into account: capital costs, fuel costs, operations and maintenance (O&M) costs. These costs are an average over the life of a project and for a specific technology, based on a specific and particular set of assumptions.

Under LCOE financial model, costs cash-flow is discounted to the present (date of commissioning) using assumed specific discount rates. The resultant LCOE values, one for each generation option, are the main driver for choice technology. The unit of measure typically used for the LCOE is USD/MWh.

Investment costs are probably the most important element in any investment decision. They vary greatly from technology to technology, from time to time and from country to country. "Overnight cost" is a common unit of measure of power investments. The Overnight cost is the cost of a construction project if no interest was incurred during construction, as if the project was completed "overnight." The unit of measure typically used for the Overnight cost is USD/kW.

In a traditional context of integrated monopoly, regulated electricity prices charged to consumers reflected long-term average cost of producing electricity. In the competitive generation markets, relationship between average costs and prices is no longer obvious. Prices are set by the marginal cost of the last dispatched technology and once a power plant is built, investment is considered "sunk costs".

The notion of LCOE generation is a handy tool for comparing the unit costs of different power generation technologies but it need to be aware of the limitations of the data.

2.2 Overview of Recent LCOE Analyses

Recently, different authoritative institutions released analysis regarding the future LCOE generation:

- in November 2008 the European Commission (EC) [7],
- in January 2010 the U.S. Energy Information Administration (EIA) [8], and
- in March 2010, the OECD/IEA-NEA (IEA) [6].

Each of these analyses adopts little difference with regard to LCOE definition; to elements included in LCOE formula (only EIA [8] included "Transmission Investment"); to assumptions adopted.

With regard of assumptions adopted, we note many differences. Year of reference is 2015 for IEA [6], 2020 and 2030 for EC [7], and 2016 for EIA [8]. Discount rate is 5% and 10% for IEA [6], 10% for EC [7], and an annual WACC in a nominal 10%-12% range for EIA [8]. Currency is EUR for EC [7], USD for IEA [6] and EIA [8]. The geographic area is world for IEA [6], EU27 for EC [7], U.S. for EIA [8]. Cost of fuel and price of electricity assumptions are different.

The Fuel Cell technology is included in different way in these analyses. In Reference [7] (EC) the Fuel Cell technology is not considered. In Reference [8] (EIA) Fuel Cell is not included in the final table published in the web but is considered in the Assumption Report [9] and Spreadsheet [10]. In Reference [6] (IEA) the Fuel Cell technology is considered and included in the analysis.

In detail, the *EC analysis* [7], synthesized in Table 1 (in next page), includes two fuel price scenarios: *Moderate* (oil barrel at 54.5 USD in 2007, 61 USD in 2020 and 63 USD in 2030) and *High* (oil barrel at 54.5 USD in 2007, 100 USD in 2020 and 119 USD in 2030). In this analysis, carbon costs are were considered only for the projected LCOE in 2020 and 2030. It was assumed that each ton of CO₂ directly emitted from the facility was charged with 41 EUR/tCO₂ in 2020 and 47 EUR in 2030.

With regard to the *U.S. EIA analysis* [8], summarized in Table 2 (in next page), it includes in the Total System Levelized Cost also the Transmission Investment. A 3-percentage point increase in the cost of capital is added when evaluating investments in GHG intensive technologies like coal-fired power plants without carbon control and sequestration (CCS) and coal-to-liquids plants. The 3-percentage point adjustment has, in levelized cost terms, an impact similar to that of a 15 USD/tCO₂ emissions fee applied to investment in a new coal plant without CCS.

| Energy Source | Power Generation Technology | Overnight Cost (EUR/kW) | | Levelized Production Cost of Electricity (EUR/MWh) | | | | | |
|---------------|---|-------------------------|-------------|--|-----------------|-----------|--------------------------|-----------------|-----------|
| | | Capital Investment Cost | | Moderate Fuel Price Scenario | | | High Fuel Price Scenario | | |
| | | Status of Art 2007 | Ref. | Range | Projection for: | | | Projection for: | |
| | | | | 2007 | 2020 | 2030 | 2007 | 2020 | 2030 |
| Coal | Pulverised Coal Combustion (PCC) | 1265 | 1000 - 1440 | 40 - 50 | 65 - 80 | 65 - 80 | 40 - 55 | 80 - 95 | 85 - 100 |
| | PCC with CCS | 2250 | 1700 - 2700 | na | 80 - 105 | 75 - 100 | na | 100 - 125 | 100 - 120 |
| | Circulating Fluidised Bed Combustion (CFBC) | 1400 | 1250 - 1500 | 45 - 55 | 75 - 85 | 75 - 85 | 50 - 60 | 95 - 105 | 95 - 105 |
| | Integrated Gasification Combined Cycle (IGCC) | 1550 | 1400 - 1650 | 45 - 55 | 70 - 80 | 70 - 80 | 50 - 60 | 85 - 95 | 85 - 95 |
| | IGCC with CCS | 2100 | 1700 - 2400 | na | 75 - 90 | 65 - 85 | na | 95 - 110 | 90 - 105 |
| Gas | Open Cycle Gas Turbine (GT) | 310 | 200 - 400 | 65 - 75 | 90 - 95 | 90 - 100 | 80 - 90 | 145 - 155 | 160 - 165 |
| | Combined Cycle Gas Turbine (CCGT) | 635 | 470 - 730 | 50 - 60 | 65 - 75 | 70 - 80 | 60 - 70 | 105 - 115 | 115 - 125 |
| | CCGT with CCS | 1200 | 1000 - 1440 | na | 85 - 95 | 80 - 90 | na | 130 - 140 | 140 - 150 |
| Oil | Internal Combustion Diesel Engine | 800 | 550 - 1350 | 100 - 125 | 140 - 165 | 140 - 160 | 125 - 145 | 200 - 220 | 230 - 250 |
| | Combined Cycle Oil-fired Turbine | 1000 | 900 - 1100 | 95 - 105 | 125 - 135 | 125 - 135 | 115 - 125 | 175 - 185 | 200 - 205 |
| Nuclear | Nuclear Fission | 2680 | 1970 - 3380 | 50 - 85 | 45 - 80 | 45 - 80 | 55 - 90 | 55 - 90 | 55 - 85 |
| Wind | On-shore | 1140 | 1000 - 1370 | 75 - 110 | 55 - 90 | 50 - 85 | 75 - 110 | 55 - 90 | 50 - 85 |
| | Off-shore | 2000 | 1750 - 2750 | 85 - 140 | 65 - 115 | 50 - 95 | 85 - 140 | 65 - 115 | 50 - 95 |
| Solar | Photovoltaic | 4700 | 4100 - 6900 | 520 - 880 | 270 - 460 | 170 - 300 | 520 - 880 | 270 - 460 | 170 - 300 |
| | Concentrating Solar Power | 5000 | 4100 - 6000 | 170 - 250 | 110 - 160 | 100 - 140 | 170 - 250 | 130 - 180 | 120 - 160 |
| Biomass | Solid Biomass | 3800 | 2090 - 5080 | 80 - 195 | 85 - 200 | 85 - 205 | 80 - 195 | 90 - 215 | 95 - 220 |
| | Biogas | 3140 | 2960 - 5790 | 55 - 215 | 50 - 200 | 50 - 190 | 55 - 215 | 50 - 200 | 50 - 190 |
| Hydro | Large | 1350 - 2510 | 900 - 4500 | 35 - 145 | 30 - 140 | 30 - 130 | 35 - 145 | 30 - 140 | 30 - 130 |
| | Small | 2900 - 4500 | 2000 - 6600 | 60 - 185 | 55 - 160 | 50 - 145 | 60 - 185 | 55 - 160 | 50 - 145 |

| Plant Type | Plant Size (MW) | Overnight Cost in 2009 (USD/kW) | | | | Levelized Production Cost of Electricity (USD/MWh) | | | | |
|--------------------------------------|-----------------|---------------------------------|----------------------------|-------------------------------|-----------------------------------|--|-----------|-------------------------------|--------------|-----------------------------|
| | | Overnight Cost (2008USD/kW) | Project Contingency Factor | Technological Optimism Factor | Final Overnight Cost (2008USD/kW) | Levelized Capital Costs | Fixed O&M | Variable O&M (including fuel) | | Total System Levelized Cost |
| | | | | | | | | Investment | Transmission | |
| Conventional Coal | 600 | 2078 | 1,07 | 1,00 | 2223 | 69,2 | 3,8 | 23,9 | 3,6 | 100,5 |
| Advanced Coal | 550 | 2401 | 1,07 | 1,00 | 2569 | 81,2 | 5,3 | 20,4 | 3,6 | 110,5 |
| Advanced Coal with CCS | 380 | 3427 | 1,07 | 1,03 | 3776 | 92,6 | 6,3 | 26,4 | 3,9 | 129,2 |
| Conventional Gas Combined Cycle | 250 | 937 | 1,05 | 1,00 | 984 | 22,9 | 1,7 | 54,9 | 3,6 | 83,1 |
| Advanced Gas Combined Cycle | 400 | 897 | 1,08 | 1,00 | 968 | 22,4 | 1,6 | 51,7 | 3,6 | 79,3 |
| Advanced Gas Combined Cycle with CCS | 400 | 1720 | 1,08 | 1,04 | 1932 | 43,8 | 2,7 | 63,0 | 3,8 | 113,3 |
| Conventional Combustion Gas Turbine | 160 | 653 | 1,05 | 1,00 | 685 | 41,1 | 4,7 | 82,9 | 10,8 | 139,5 |
| Advanced Combustion Gas Turbine | 230 | 617 | 1,05 | 1,00 | 648 | 38,5 | 4,1 | 70,0 | 10,8 | 123,4 |
| Advanced Nuclear | 1350 | 3308 | 1,10 | 1,05 | 3820 | 94,9 | 11,7 | 9,4 | 3,0 | 119,0 |
| Fuel Cells (Molten Carbonate) | 10 | 4744 | 1,05 | 1,10 | 5478 | | | | | |
| Wind | 50 | 1837 | 1,07 | 1,00 | 1966 | 130,5 | 10,4 | | 8,4 | 149,3 |
| Wind - Offshore | 100 | 3492 | 1,10 | 1,02 | 3937 | 159,9 | 23,8 | | 7,4 | 191,1 |
| Solar PV | 5 | 5879 | 1,05 | 1,00 | 6171 | 376,8 | 6,4 | | 13,0 | 396,2 |
| Solar Thermal | 100 | 4798 | 1,07 | 1,00 | 5132 | 224,4 | 21,8 | | 10,4 | 256,6 |
| Geothermal | 50 | 1666 | 1,05 | 1,00 | 1749 | 88,0 | 22,9 | | 4,8 | 115,7 |
| Biomass | 80 | 3414 | 1,07 | 1,05 | 3849 | 73,3 | 9,1 | 24,9 | 3,8 | 111,1 |
| Hydro | 500 | 2084 | 1,10 | 1,00 | 2291 | 103,7 | 3,5 | 7,1 | 5,7 | 120,0 |

The *OECD/IEA-NEA analysis* [6] presents detailed data on electricity generating costs for 190 power plants in 17 OECD countries and 4 non-OECD (Brazil, China, Russia and South Africa).

Table 3 (in next page) is our re-elaboration of these plants data (with exclusion of the 20 CHP plants data). The LCOE calculated are at plant-level costs and do not include transmission and distribution costs. This analysis assumes a carbon price of USD 30 per ton of CO₂ emitted and includes two discount rate scenarios: 5% and 10%.

2.3 Main Conclusion from LCOE Overview

At the end of this LCOE analyses overview, it is evident a wide dispersion of data and there is no technology that has a clear overall advantage globally or even regionally.

Results are particularly sensible to the fuel and electricity price assumptions. Discount rate level is another key element. Results vary from analysis to analysis, from country to country, and even within the same region, there are significant variations in the cost for the same technologies. Country-specific

Table 3 - Our Re-Elaboration of LCOE and Other Data of New OECD Generation Plants Entering Service in 2015. Reference [6], OECD/IEA-NEA 2010 Plants Data

| Plant Type | Plant Size (MW) | Overnight Cost (USD/kW) | Levelized Production Cost of Electricity (USD/MWh) | |
|-----------------|-----------------|-------------------------|--|-----------------|
| | | | LCOE 5% | LCOE 10% |
| Coal | 300 - 1312 | 807 - 4671 | 53,97 - 120,01 | 67,34 - 141,64 |
| Coal with CC(S) | 255 - 970 | 3223 - 6268 | 56,62 - 102,59 | 82,42 - 152,27 |
| Gas Turbine | 150 - 230 | 520 - 649 | 91,48 - 118,77 | 95,08 - 122,61 |
| CCGT | 395 - 1600 | 635 - 1622 | 67,03 - 105,14 | 73,36 - 119,53 |
| CCGT with CC(S) | 387 - 400 | 1928 - 2611 | 91,90 - 98,21 | 104,19 - 117,90 |
| Oil Engine | 83 | 1817 | 104,63 | 119,03 |
| Nuclear | 954 - 1650 | 1556 - 5863 | 29,05 - 78,24 | 42,09 - 136,50 |
| Fuel Cells | 10 | 5459 | 181,17 | 213,14 |
| Wind | 2 - 150 | 1912 - 3716 | 48,39 - 162,90 | 70,47 - 234,32 |
| Wind - Offshore | 3,6 - 400 | 3824 - 6083 | 101,02 - 188,21 | 146,44 - 260,80 |
| Solar PV | 0,03 - 10 | 3267 - 7381 | 215,45 - 626,87 | 332,78 - 934,63 |
| Solar Thermal | 1 - 100 | 4347 - 5255 | 136,16 - 211,18 | 202,45 - 323,71 |
| Geothermal | 5 - 500 | 1752 - 12887 | 32,48 - 164,78 | 46,76 - 269,93 |
| Biomass | 11 - 80 | 3830 - 7431 | 53,77 - 160,50 | 80,82 - 197,04 |
| Hydro | 0,3 - 1000 | 2703 - 19330 | 34,74 - 231,63 | 70,89 - 459,32 |

circumstances determine the LCOE and it is very difficult to generalize on costs.

Analyzing data calculated with different discount rate (when available), it appears clear that all the capital-intensive technologies are advantaged with low discount rates. At higher rates, coal and gas (without CCS) will be more competitive.

3. Considering Hydrogen Fuel Cells Powertrain as Power Generation Plant

3.1 Fuel Cells

A Fuel Cell is a device that uses a fuel and oxygen to create electricity by an electrochemical process, without combustion. Fuel Cells are classified primarily by the kind of electrolyte they employ: *Phosphoric Acid Fuel Cells* (PAFC), *Alkaline Fuel Cells* (AFC), *Molten Carbonate Fuel Cells* (MCFC), *Solid Oxide Fuel Cells* (SOFC), *Direct Methanol Fuel Cells* (DMFC) and *Polymer Electrolyte Membrane* (PEM) *Fuel Cells* (also called *Proton Exchange Membrane Fuel Cells*).

Today Fuel Cells are present in a wide range of prototype and products: portable applications, micro CHP system, recreation products, vehicles, niche and professional application, military items.

In presence of a so this wide context of application, why consider the Hydrogen Fuel Cell (PEM) Powertrain (H2FC Powertrain) as Power Generation Plant? Because, according with Reference [11], if the current U.S. Hydrogen and Fuel Cell Vehicle program will be able to met all the 2015 technological targets, in the subsequent year, the high volume associates with the H2FC vehicles mass production (over 500.000 unit sold per year) will permit to reduce dramatically the

Fuel Cell system manufacturing costs. In this way, the H2FC Powertrain will be so cost competitive to be useful adopted also for stationary power generation application [12].

In this high projected volume production context, adopting the H2FC Powertrain as power generation plants, the investments cost component in the LCOE value will be at one of the lowest level compared with current technologies.

3.2 The H2FC Powertrains LCOE

In order to consider a H2FC Powertrain as Power Generation Plant it is necessary to calculate its specific LCOE and, for this reason, we need some H2FC Powertrains data: the system cost (Overnight and Levelized); the expected system lifetime; the system efficiency and the fuel cost (hydrogen cost).

3.2.1 The 2009 Public Data

Based on projected high volume public data (References [13 and 14]), we find these values for year 2009: Overnight cost 61 USD/kW, Levelized Capital cost 24,2 - 24,4 USD/MWh, Lifetime 2500 - 2521 hours, 53%-59% System Efficiency, and 3 UDS/GGE Hydrogen cost.

With regard to Hydrogen cost, Reference [14] presented, for on-site natural gas reformation, an Hydrogen cost at station in a range of 7,7 - 10,3 USD/GGE. This range appears completely out of target but it is a real early market data. In the same context, Reference [14] observe that, a DOE independent panels [15] confirmed at 500 replicate stations/year with 1500 kg/day distributed natural gas reformation, an Hydrogen Cost at Station in a range of 2,75 - 3,50 USD/kg (USD/GGE). In U.S. market the assumption for the cost of the natural gas and electricity, specifically whether industrial rates or commercial rates were applicable, is

| H2FC Powertrain Efficiency | H2FC Powertrain Hours LIFE | Hydrogen Cost USD/GGE ^o | Capital Overnight OVN Cost (USD/kW) [^] | Levelized Capital Cost LCC (USD/MWh) | O&M + Others (Assumed Equal to 10% LCC, USD/MWh) | Fuel Cost (USD/MWh) | Levelized Cost of Electricity LCOE (USD/MWh) | |
|----------------------------|----------------------------|------------------------------------|--|--------------------------------------|--|---------------------|--|------------------|
| 53% | 2500 | 3,0 | 61 | 24,4 | 2,4 | 169,8 | 196,7 | 2009 DOE status |
| 59% | 2500 | 3,0 | 61 | 24,4 | 2,4 | 152,5 | 179,4 | 2009 DOE status |
| 53% | 2521 | 3,0 | 61 | 24,2 | 2,4 | 169,8 | 196,4 | 2009 DOE status |
| 59% | 2521 | 3,0 | 61 | 24,2 | 2,4 | 152,5 | 179,2 | 2009 DOE status |
| 60% | 5000 | 3,0 | 30 | 6,0 | 0,6 | 150,0 | 156,6 | 2015 DOE targets |
| 60% | 5000 | 2,0 | 30 | 6,0 | 0,6 | 100,0 | 106,6 | 2015 DOE targets |

[^] Projected, high-volume manufacturing cost of automotive H2FC systems

^o Distributed Natural Gas Reforming status and targets assume station capacities of 1500 kg/day, with 500 stations built per year

not clear cut. In this sense, in order to reduce the distributed natural gas reformation Hydrogen price, is fundamental to reach 500 new delivery stations per year and, in this way, obtain the industrial gas price rate, much lower than the commercial gas rate, and consequently reduce the Hydrogen production costs.

3.2.2 The 2015 Targets

Based on the same projected high volume assumption, we adopt the U.S. DOE technical targets (Reference [16]) for year 2015: Overnight cost 30 USD/kW, Levelized Capital cost 6 USD/MWh, Lifetime 5000 hours, 60% System Efficiency, and 2 - 3 UDS/GGE Hydrogen cost.

Considering high H2FC Powertrain stress connects with transportation application, the expected lifetime system in stationary application should be much higher than 5000 hours, nevertheless, in our analyses, we consider only U.S. DOE targets.

According to Reference [13], the lower value of the Hydrogen cost range (2 UDS/GGE) is referred to coal gasification with CO₂ sequestration Hydrogen production.

3.2.3 Other Consideration and Assumption

Thanks to the fact that the expected system life is shorter than one year (also in 2015), it is not necessary to consider any financial aspect.

With regards of Operations and Maintenance (O&M) and Other costs, we assumed these costs as equal to 10% of Levelized Capital Cost.

Considering the fact that H2FC Powertrain is a completely new technology in our analysis we compare our H2FC powertrain LCOE data with the high-discount rate analyses data (when available).

Even if we have in mind H2FC Powertrain thermal management issues and also the possibility, if the H2FC Powertrain system will be specially equipped for that, to recover the heat co-produced during the electricity generation (like in a CHP power plant), our simply and preliminary analysis do not take in consideration these aspects. In addition, we do not considering any possible cost related to the vehicle-to-grid electrical connection outlet.

3.2.4 Results

For 2009 we find the LCOE H2FC Powertrain value in a range of 179,2 -196,7 USD/MWh.

For year 2015, we find the LCOE H2FC Powertrain value in a range of 106,6-156,6 USD/MWh.

Table 4 shows our estimated H2FC Powertrain LCOE.

4. Conclusion

Based only on public data, H2FC Powertrain is considered as power generation plant and the cost of electricity production is compared with the generation costs of the traditional power generation technologies in a simple and preliminary analysis.

Using only 2009 tested U.S. DOE H2FC Powertrain data (referred to high projected production volume) we found that the cost generating baseload electricity (LCOE) would be in a range of USD 179,2 -196,7 for MWh.

Comparing this cost range with the LCOE published in the most recent studies, we observe that H2FC Powertrain generation would be at lower cost than wind offshore, solar thermal and solar photovoltaic.

Using the 2015 U.S. DOE data target the of H2FC Powertrain the LCOE electricity production cost range moves to USD 106,6-156,6 for MWh, and, in most of the context, it appears competitive with all the power generation technologies.

These preliminary results suggest that further investigation is needed.

References

- [1] W. Kempton, *Electric vehicles as a new power source for electric utilities*, Transportation Research Part D 2, 1997, <http://www.udel.edu/V2G/docs/Kempton-Letendre-97.pdf>, accessed on 2010/05/16.
- [2] Institute of Transportation Studies, University of

- California, Davis "Vehicle-to-Grid Power: Battery, Hybrid, and Fuel Cell Vehicles as Resources for Distributed Electric Power in California", 2001, http://pubs.its.ucdavis.edu/publication_detail.php?id=360, accessed on 2010/05/16.
- [3] W. Kempton, J. Tomić "Vehicle to Grid Implementation: from stabilizing the grid to supporting large-scale renewable energy", *Journal of Power Sources* Volume 144, 2005, http://www.spinovation.com/sn/Articles_on_V2G/Vehicle-to-grid_power_implementation_From_stabilizing_the.pdf, accessed on 2010/05/16.
- [4] T. Lipman, J. Edwards, D. Kammen, "Economic Implications of Net Metering for Stationary and Motor Vehicle Fuel Cell Systems in California", 2002, <http://www.ucei.berkeley.edu/PDF/pwp092.pdf>, accessed on 2010/05/16.
- [5] W. Kempton, J. Tomić, "Vehicle-to-grid power fundamentals: Calculating capacity and net revenue", *Journal of Power Sources*, Volume 144, 2005, http://www.spinovation.com/sn/Articles_on_V2G/Vehicle-to-grid_power_fundamentals_Calculating_capacity.pdf, accessed on 2010/05/16.
- [6] Organization for Economic Co-operation and Development (OECD) / International Energy Agency (IEA) – Nuclear Energy Agency (NEA): "Projected Costs of Generating Electricity" 2010 Edition, Paris, France March 2010, ISBN 978-92-64-08430-8.
- [7] European Commission: "Energy Sources, Production Costs and Performance of Technologies for Power Generation, Heating and Transport", COM(2008)744, Brussels, Belgium November 2008, http://ec.europa.eu/energy/strategies/2008/doc/2008_11_ser2/strategic_energy_review_wd_cost_performance.pdf, accessed on 2010/08/13.
- [8] U.S. Energy Information Administration (EIA): "2016 Levelized Cost of New Generation Resources from the Annual Energy Outlook 2010" Washington, January 2010, http://www.eia.doe.gov/oiaf/aeo/electricity_generation.html, accessed on 2010/05/30.
- [9] U.S. Energy Information Administration (EIA) "Assumptions to the Annual Energy Outlook 2010" April 2010, [http://www.eia.doe.gov/oiaf/aeo/assumption/pdf/0554\(2010\).pdf](http://www.eia.doe.gov/oiaf/aeo/assumption/pdf/0554(2010).pdf), accessed on 2010/08/18.
- [10] U.S. Energy Information Administration EIA "Table 8.2 Cost and Performance Characteristics of New Central Station Electricity Generating Technologies" January 2010, <http://www.eia.doe.gov/oiaf/aeo/excel/aeo2010%20tab8%202.xls>, accessed on 2010/04/30.
- [11] M. V. Romeri, Paper "Hydrogen and Fuel Cells Vehicles in the Post Kyoto Perspective", National Hydrogen Association 2010 XXI Hydrogen Conference & Expo "green energy. green jobs. green planet." Long Beach CA U.S.
- [12] U. S. Department of Energy U.S. DOE "Effects of Transition to a Hydrogen Economy on Employment in the United States Report to Congress" Washington, October 2008, http://www.hydrogen.energy.gov/pdfs/epact1820_employment_study.pdf, accessed on 2009/04/20.
- [13] S. Satyapal "Overview of United States Hydrogen and Fuel Cell Activities" U.S. DOE, Joint 12th IPHE Meeting, Washington, December 2009, http://www.iphe.net/docs/Meetings/USA_12-09/Country_Presentations/DOE%20Overview%20IPHE%202009%20Satyapal.pdf, accessed on 2010/05/16.
- [14] K. Wipke "Controlled Hydrogen Fleet and Infrastructure Analysis, U.S. DOE National Renewable Energy Laboratory (NREL), Annual Merit Review, Washington, June 2010, http://www.hydrogen.energy.gov/pdfs/review10/tv001_wipke_2010_o_web.pdf, accessed on 2010/08/13.
- [15] "Distributed Hydrogen Production from Natural Gas – Independent Review" U.S. DOE Hydrogen Program, NREL, Colorado, October 2006, <http://www.hydrogen.energy.gov/pdfs/40382.pdf>, accessed on 2010/08/21.
- [16] U. S. Department of Energy U.S. DOE "Report to Congress Hydrogen and Fuel Cell Activities, Progress, and Plans", Washington, January 2009, http://www.hydrogen.energy.gov/pdfs/epact_report_sec811.pdf, accessed on 2009/06/11.

Authors

Mario Valentino Romeri is independent consultant. He graduated in Business Administration from the L. Bocconi University of Milan in 1987. He spent most of his working life in the Allianz SE Group. He started as financial analyst, moves to senior equity analyst and then was responsible of "Analysis Research and Advisory" unit, with focus in new and renewable energy.