

Supplementary Materials

Removal of Organic Micropollutants by Grainy Bentonite-Activated Carbon Adsorbent in a Fixed Bed Column

Gabriela Kamińska

Institute of Water and Wastewater Engineering, Silesian University of Technology, 44-100 Gliwice, Poland

* Correspondence: gabriela.kaminska@polsl.pl; Tel.: +48-32-237-27-77

Table S1. Reduction degree at flow 6 mL/min.

	Column I	Column II	Column III
Colour	29%	36%	39%
Absorbance	21%	25%	37%
Phenolic index	12%	21%	20%